

6/22/2020

To: *Whom it may concern:*

From:



*Bill Baldwin*

Subject: *Concession booth rules and regulations.*



All concessions using fryalators and deep fat fryers shall have a CLASS-K foam fire extinguisher. Anyone that doesn't have a CLASS-K extinguisher will not be able to use their deep fat fryers or fryalators as referenced by Connecticut Fire Safety code NFPA 10.

The use of extension cords shall be only number 12 or 14 wire heavy duty only and they shall be in good working condition.

All L.P. portable tanks shall be secured in milk crates or tied to stakes to prevent them from tipping over and all the connection lines shall be tight and tested with soap to insure there is no leakage. NOTE: All L.P. tanks shall be less than 12 years old.

If there are any questions please feel free to contact me, Cell phone 860-601-8940